

17-8-82  
10.3.8 v.3

Interoffice Memo



# LONE STAR INDUSTRIES, INC.

One Greenwich Plaza, Greenwich, Connecticut 06830

Originating Office: Seattle Cement Plant

Date: November 8, 1982

TO: T. G. Wells  
FROM: K. J. Rone  
SUBJECT: #2 Finish Mill

Work began last Friday on restoring #2 finish mill systems after the severe duty they have experienced since August. Work will be as follows:

## Week of November 8, 1982

## Dept. Responsibility

Repair splice - incline belt  
Overhaul F.K. pump motor  
Repair feeder #5, bad roller  
Repair feeder #5, worn metalwork  
Clean water jacket, #2 compressor  
Clean out clutch  
Install brackets for clutch airlines  
#4 cooler - P.M. gearbox, fix plumbing  
Repair all liner bolts  
Elevator leaks - 1st and 2nd floor  
Elevator inspection  
Hydro clean F.K. convey line  
P.M. compressor and blower filters  
Repair cement cooler water distribution  
Separator P.M. and inspection  
Clean out oil coolers  
Install #4 cooler extension  
Inspect Symetro bearing  
Inspect discharge journal  
Airslide inspection

R  
E  
R  
R  
R  
R  
R  
R  
R  
R  
Y  
R  
Y  
R  
R  
R  
Y  
R

#2 ELEVATOR GEAR REDUCER - LEAKS

## Wednesday, November 10, 1982

Change out #1 compressor  
Change out #1 F.K. pump motor & MOTOR BASE  
Repair tripper - leaks, wheels, roller support  
Water tank cleanout  
#1 weigh screw leak

R  
R  
R  
Y  
R

KJR/mme

USEPA SF  
  
1261058